



## **Addendum #4**

Bid Number 23/24-23  
Stauffer Middle School Softball Synthetic Field

The changes made under this Addendum of the Contract Documents, Specifications, Special Provisions, and Plans for the above project Bid Packet are as follows:

### **Item 1. Pre-Bid RFIs:**

1. Bid docs state to remove and replace chain link fencing. Removing just the chain link fabric to replace or posts as well? Didn't see a spec if we have to replace posts. Backstop too?

**RESPONSE:** Replace chain link fence panels. Posts to remain in place. Backstop and batting cages included. Softball field is 760 lineal feet and batting cage is 175 lineal feet.

END OF DOCUMENT